



CE 1837

EC TYPE-EXAMINATION CERTIFICATE

No: 1837-PED- 0072

Manufacturer's Company name and address:	TODOROVIC D.O.O. Industrijska 7, 3400 Kragujevac - Republika Serbia
Manufacturing Plant:	TODOROVIC D.O.O. Industrijska 7, 3400 Kragujevac - Republika Serbia
Product/Type designation:	Fire-extinguisher: - S POWDER - 1, 2, 3, 6, 9, 12, 50, 100 kg. - S FOXER - 2, 6 kg.
Max. Operating Pressure (Mpa):	1,8
Max. Operating Temperature (°C):	-30 - +60
Category of the Equipment:	III
Conformity Report No:	74/05.06.2011 г.

The "ITEM-Consult" Ltd confirms that after carried out procedure "EC Type examination"- module B, the examined pressure equipment "Fire-extinguisher Type S POWDER - 1, 2, 3, 6, 9, 12, 50, 100 kg. and S FOXER – 2, 6 kg ", fulfill the essential requirements of Directive 97/23/EC, introduced by "Regulation of essential requirements and conformity assessment of pressure equipments.

Validity: 10 years

Sofia, Bulgaria, 06.06.2011 г.
(Place and date of issue)

Director of the Notified Body:

(Ing. Milanov)

