



CE 1837

EC TYPE-EXAMINATION CERTIFICATE

No: 1837-PED- 0073

Manufacturer's Company name and address:	TODOROVIC D.O.O. Industrijska 7, 3400 Kragujevac - Republika Serbia
Manufacturing Plant:	TODOROVIC D.O.O. Industrijska 7, 3400 Kragujevac - Republika Serbia
Product: Type:	Fire-extinguisher CO ₂ - 5,10, 30 kg.: - CO ₂ – 5/SA 01 - CO ₂ – 10/SA 01 - CO ₂ – 30/SA 01
Max. Operating Pressure (Mpa):	17,4
Max. Operating Temperature (°C):	-30 - +60
Category of the Equipment:	III
Conformity Report No:	75/02.06.2011 r.

The "ITEM-Consult" Ltd confirms that after carried out procedure "EC Type examination"- module B, the examined pressure equipment "Fire-extinguisher CO₂ - 5,10, 30 kg. Type CO₂ – 5/SA 01, CO₂ – 10/SA 01 and CO₂ – 30/SA 01", fulfill the essential requirements of Directive 97/23/EC, introduced by "Regulation of essential requirements and conformity assessment of pressure equipments.

Validity: 10 years

Sofia, Bulgaria, 08.06.2011 r.
(Place and date of issue)

Director of the Notified Body:

(Ing. Milanov)

