



CERTIFICATE

For "Internal manufacturing checks with monitoring of the final assessment – Module A1"

No: 1837-PED-0089

Manufacturer's Company name and address:	ARES PLAKALI EŞANJÖR SAN. VE TİC. LTD. ŞTİ. H.S.O S.B. Ordu Cad. No:4 Sarıçam - Adana/Turkey
Manufacturing Plant:	ARES PLAKALI EŞANJÖR SAN. VE TİC. LTD. ŞTİ. H.S.O.S.B. Ordu Cad. No:4 Sarıçam - Adana/Turkey
Product:	Plate Heat Exchanger
Type Designation:	Seri A: PN 10; PN 25
Maximum operating pressure (MPa):	1,0 and 2,5
Maximum operating temperature (°C):	180
Conformity Report №:	91/06.12.2011г.

The "ITEM-Consult" confirms that after carried out procedure "Internal manufacturing checks with monitoring of the final assessment - Module A1", the examined pressure equipment "Plate Heat Exchanger Ser: A: PN 10; PN 25", fulfill the essential requirement of Directive 97/23/EC, introduced by "Regulation of essential requirements and conformity assessment of pressure equipment" and admit manufacturer to be in the right to enter indicated Identification Number.

Validity: 06.12.2012 г.

Sofia, Bulgaria. 07.12.2011 г.
(Place and date of issue)

Director of the Notified Body:

(Ing. A. Milanov)

No:1837-PED-0089
page 1/1