



"ITEM – Consult"
Notified Body for Pressure Vessels
and Pressure Equipments

CE1837

C E R T I F I C A T E

EU TYPE-EXAMINATION - PRODUCTION TYPE

No: 1837-PED- 0245

Manufacturer's Company name and address:	CV Fire – fire fighting equipments manufacturing, sociedade unipessoal, Lda
Productio site:	Achada grande de tras, Praia, Ilha de Santiago, Cape Verde
Product/Type designation:	Fire extinguisher: CVF-P06 - PED-0245(27A. 144B. C)
Max. Operating Pressure (Mpa):	1,8
Max. Operating Temperature (°C):	-20 ÷ +60
Category of the Equipment:	III
Testing standards	EN 3-7, E 3-8, EN 3-10
Conformity Report №:	250/26.01.2022

The "ITEM-Consult" confirms that after carried out procedure "EC Type-examination-modul B", the examined pressure equipment "fire-extinguisher Type CVF-P06-PED-0245 (27A. 144B. C).", fulfill the essential requirements of Directive 2014 /68 /EU, introduced by "Regulation of essential requirements and conformity assessment of pressure equipments.

Validity:: 10 years

27.01.2022 r.
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM-Consult" Ltd:

(eng. L.Vasilev)