



"ITEM – Consult"
Notified Body for Pressure Vessels
and Pressure Equipments

CE1837

CERTIFICATE

EU TYPE-EXAMINATION - PRODUCTION TYPE

No: 1837-PED- 0245 Rev.01

Manufacturer's
Company name and address: CV Fire – fire fighting equipments
manufacturing, sociedade unipessoal, Lda

Productio site: Achada grande de tras, Praia, Ilha de
Santiago, Cape Verde

Product/Type designation: Fire extinguisher:
CVF-P06 - PED-0245(27A. 144B. C)
CVF-A06L-PED-2045(27A. 144B. 75F)

Max. Operating Pressure (Mpa): 1,8

Max. Operating Temperature (°C):

Temperature	T _{min}	T _{max}
CVF-P06-PED 0245	-20	+ 60
CVF-A06L-PED-2045	0	+ 60

Category of the Equipment: III

Testing standards EN 3-7, E 3-8, EN 3-10

Conformity Report No: 252/08.03.2022

The "ITEM-Consult" confirms that after carried out procedure "EC Type-examination-modul B", the examined pressure equipment "fire-extinguisher Type CVF-P06-PED-0245 (27A. 144B. C; CVF-A06L-PED-2045(27A. 144B. 75F)", fulfill the essential requirements of Directive 2014 /68 /EU, introduced by "Regulation of essential requirements and conformity assessment of pressure equipments.

Validity:: 10 years (26.01.2022)

09.03.2022 r.
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM-Consult" Ltd:

(eng. L. Vasilev)