„ITEM Consult" Ltd
Notified Body for Gas Appliances and
Pressure Vessels and Equipments

CE 1837

СЕРТИФИКАТ

Модул В: ЕС Изследване на типа –
Изследване на типа произведен продукт

CERTIFICATE

MODULE B: EU TYPE-EXAMINATION - PRODUCTION TYPE

№: 1837-GU-0382 Rev 1

Име и адрес на производителя: **Manufacturer's** **Company name and address:**	„MYTHERM SINGLE MEMBER PC", Industrial Area Sindos, Thessaloniki-57008 Greece
Газов уред / Product:	CONDENSING GAS BOILER – series GM
Модели: **Models specification:**	25/30/35/40 kW - **stated on page 2**
Търговско наименование: **Commercial name:**	**Danae, Ilione**
Стандарт на изпитване: **Basis of Examination:**	БДС EN 303-1:2017; БДС EN 303-3:2001; БДС EN 13203-1:2015; БДС EN 13203-2:2019; БДС EN 15502-1:2012+A1:2015; БДС EN 15502-2 1:2012+A1:2017
Категория на газовия уред: **Category of the gas product:**	$II_{2H3B/P}$ | AT, BE, BG, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, IE, IT, LT, LU, LV, NO, PL, PT, SE, SI, SK, TR
P.I.N. / Identification Number:	**1837DO0452**
Доклад от оценка №: **Conformity Report №:**	439/24.01.2023

"ITEM Consult" Ltd hereby confirms, that after carried out procedure Module B: "EU Type Examination – Production type", the examined gas appliance "CONDENSING GAS BOILER – GM 25/30/35/40 kW" fulfill the essential safety requirements of REGULATION (EU) 2016/426, introduced by "Regulation of essential requirements and conformity assessment of gas appliances burning gaseous fuels".
This certificate does not allow to affix the identification number 1837 of the Notified Body.

Валиден до: 24.06.2031
Valid until:

25.01.2023
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM Consult"Ltd:
(Eng. L.Vasilev)

"ИТЕМ КОНСУЛТ" ЕООД
София

"ITEM Consult" Ltd, Sofia1220, bul."Istoria Slavyanobulgarska" №8
Tel.+359 2 832 50 08; Fax.+359 2 931 03 59
E-mail: consult@item-bg.com; Web: www.item-bg.com

PRODUCT SPECIFICATIONS

MODEL	Gas Type	Gas supply pressure	Thermal Heating Output	D.H.W Output	Max operat. Pressure Heating	Max operat. Pressure D.H.W
GM 25	Natural gas/ Propane LPG	20 mbar/ 37 mbar	24 kW	28 kW	3 bar	6 bar
GM 30	Natural gas/ Propane LPG	20 mbar/ 37 mbar	29 kW	35 kW	3 bar	6 bar
GM 35	Natural gas/ Propane LPG	20 mbar/ 37 mbar	34,5 kW	38 kW	3 bar	6 bar
GM 40	Natural gas/ Propane LPG	20 mbar/ 37 mbar	37 kW	40 kW	3 bar	6 bar

25.01.2023
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM Consult" Ltd:
(Eng.L.Vasilev)

"ITEM Consult" EOOD
София