„ITEM Consult" Ltd
Notified Body for Gas Appliances and
Pressure Vessels and Equipments

CE1837

СЕРТИФИКАТ

Модул В: ЕС Изследване на типа –
Изследване на типа произведен продукт

CERTIFICATE

MODULE B: EU TYPE-EXAMINATION - PRODUCTION TYPE

№: 1837-GU-0368Rev1

Име и адрес на производителя: **Manufacturer's** **Company name and address:**	"TRIO ENERJI ISITMA SOGUTMA URETIM ITHALAT IHRACAT PAZARLAMA SAN. VE TIC", Yesilkoy Mah. Ataturk Cad. EGS Business park No 12, IC Kapi No 8 Bakirkoy, Istanbul, Turkey
Газов уред / Product type:	TUBE RADIANT HEATER - TT
Модели **Models specification:**	TT 15 U, TT 20 (U-L), TT 32 (U-L), TT 38 (U-L), TT 48 (U-L) and TT 58 (U-L) - **stated on page 2**
Търговско наименование **Trade mark:**	Reflect; Tubolare; Diamond; Arsis; Megamist; Norm; Caldoria and Fertec.
Стандарт на изпитване: **Basis of Examination:**	EN 416:2019
Категория на газовия уред: **Category of the gas product:**	I_{2H} — AT, BE, BG, CH, CZ, DE, DK, EE, ES, FI, FR, GB, GR, IE, IT, LT, LU, LV, NO, PL, PT, SE, SI, SK, TR
P.I.N. / Identification Number:	**1837DO0479**
Доклад от оценка №: **Conformity Report №:**	456/28.09.2023

"ITEM Consult" Ltd hereby confirms, that after carried out procedure Module B: "EU Type Examination – Production type", the examined gas appliance "TUBE RADIANT HEATER - TT, models - TT 15 U, TT 20 (U-L), TT 32 (U-L), TT 38 (U-L), TT 48 (U-L) and TT 58 (U-L)" fulfill the essential safety requirements of REGULATION (EU) 2016/426, introduced by "Regulation of essential requirements and conformity assessment of gas appliances burning gaseous fuels".
This certificate does not allow to affix the identification number 1837 of the Notified Body.

Valid until: 18.11.2030

28.09.2023
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM Consult" Ltd:
(Eng. L.Vasilev)

"ITEM Consult" Ltd, Sofia1220, bul."Istoria Slavyanobulgarska" №8
Tel.+359 2 832 50 08; Fax.+359 2 931 03 59
E-mail: consult@item-bg.com; Web: www.item-bg.com

PRODUCT SPECIFICATION

MODELS	TT 15 U	TT 20 (U-L)	TT 32 (U-L)	TT 38 (U-L)	TT 48 (U-L)	TT 58 (U-L)
Nominal input power (KW)	15	20	32	38	48	58
Electrical Supply (Vac)	240/220-50 Hz	240/220-50 Hz	240/220-50 Hz	240/220-50 Hz	240/220-50 Hz	240/220-50 Hz
Gas pressure NG (mbar)	20	20	20	20	20	20
Gas Connection	3/4"	3/4"	3/4"	3/4"	3/4"	3/4"

28.09.2023
Sofia, Bulgaria
(Place and date of issue)

Manager "ITEM Consult" Ltd: (Eng. L.Vasilev)

"ИТЕМ Консулт" ЕООД
София